

# Attestation

## Italian CAM

On 4 October 2021, Eurofins Product Testing A/S received a sample of a coating with the product name:

**CHAR 21**

supplied by

**Iris Coatings S.R.L**

The emissions were tested according to the Italian CAM Decree GU n.23 del 28-01-2017. Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 (see the test report no. 392-2021-00482501\_A\_EN).

### **Evaluation of the emission test result according to Italian CAM:**


---

- The relevant CMR compounds were not detectable after 28 days.
  - The sum of VOC ("TVOC") after 28 days was below the limit of 1500 µg/m<sup>3</sup>.
  - Formaldehyde after 28 days was below the limit of 60 µg/m<sup>3</sup>.
  - All other parameters were below their respective limit values after 28 days.
- 

25 January 2022



Rasmus Verdier  
Analytical Service Manager



Rasmus Stengaard Christensen  
Analytical Service Manager, MSc in Chemistry