

Attestation

Italian CAM

On 11 November 2021 Eurofins Product Testing A/S received a sample of paint with the product name:

CHAR 21Plus

supplied by

Iris Coatings S.R.L

The emissions were tested according to the Italian CAM Decree GU n.23 del 28-01-2017. Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 (see the test report no. 392-2021-00561201_A_EN).


Evaluation of the emission test result according to Italian CAM:

- The relevant CMR compounds were not detectable after 28 days.
 - The sum of VOC ("TVOC") after 28 days was below the limit of 1500 µg/m³.
 - Formaldehyde after 28 days was below the limit of 60 µg/m³.
 - All other parameters were below their respective limit values after 28 days.
-

25 January 2022



Rasmus Verdier
Analytical Service Manager



Rasmus Stengaard Christensen
Analytical Service Manager, MSc in Chemistry